

SCIENTIFIC CONSULTANTS IN RISK ASSESSMENT AND MANAGEMENT, PRODUCTS, PROCESSES, OH&S, ENVIRONMENT

VOC Content Test Certificate

Tuesday April 17th, 2007

Manufacturer: Ardex Australia Pty Ltd

Unit 7, 20 Powers Road

Seven Hills NSW 2147

Sample Description: Ardex A55 self-leveling and self-smoothing compound

Production Date: March 2007

Date Tested: April 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star IEQ-13	Ardex A55
Sub-Floor Adhesive 50 grams per Litre	9 grams per Litre

Dr. Vyt Garnys PhD, BSc(Hons) AIMM, ARACI, ISIAQ ACA, AIRAH, FMA Managing Director and Principal Consultant