

VOC Content Test Certificate

Friday June 18th, 2010

Manufacturer: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills NSW 2147)

Sample Description: Ardex P82 Ultra prime water-borne two-component primer

Date Tested: June 2010 (Tested by FORAY Laboratory – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings.

Test Data:

| | |
|---|--|
| <p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</p> | <p>Ardex P82 Ultra Prime</p> |
| <p>Internal Sealer 65 grams per Litre as VOC content material</p> | <p>32 grams per Litre as VOC content material</p> |
| <p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p> | <p>Ardex P82 Ultra Prime</p> |
| <p>Internal Sealer 65 grams per Litre as VOC content material</p> | <p>32 grams per Litre as VOC content material</p> |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1006-06