

VOC Content Test Certificate

Friday May 30th, 2008

Manufacturer: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills NSW 2147)

Sample Description: Ardex Seam Tape and Ardex WPM 299 Seam Primer (system for Butynol waterproof roofing)

Date Tested: May 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ -13 Green Star Office Interiors V1.1 IEQ -11	Ardex Seam Tape & WPM 299 Seam Primer
Architectural Sealant 250 grams per Litre	50 grams per Litre
Specification Green Building Council of Australia Green Star Office Design V3 IEQ -13	Ardex Seam Tape & WPM 299 Seam Primer
Architectural Sealant 250 grams per Litre	50 grams per Litre



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0805-73