

VOC Content Test Certificate

Wednesday, 8th August 2018

Supplier: Ardex Australia Pty Ltd (7/20 Powers Road, Seven Hills, NSW, 2147, Australia).

Sample Description: Ardex WPM 710 DT Grey

Date Tested: August 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<p>Specification</p> <p>Green Building Council of Australia</p> <p>Green Star Design & As Built V1.1 13.1.1</p> <p>Green Star Interiors V1.1 12.1.1B</p>	<p>Ardex WPM 710 DT</p> <p>Grey</p>
<p>Waterproofing membranes and sealant:</p> <p>250 grams per Litre as VOC content per material</p>	<p>5 grams per Litre as VOC content</p>
<p><i>We hereby certify Ardex WPM 710 DT Grey is well below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV180834