

VOC Content Test Certificate

Wednesday, December 12, 2012

Manufacturer: Ardex Australia (Unit 7, 20 Powers Rd, Seven Hills, NSW 2147)

Sample Description: Ardex K15 Microtec

Date Tested: November 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: SCAQMD Method 303-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Ardex K15 Microtec
Sub-Floor Adhesive 50 grams per Litre as VOC content per material	5 grams per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc
Consultant

CV121116