



## ANALYSIS CERTIFICATE

25 July, 2022

|          |               |
|----------|---------------|
| OUR REF: | 107772C       |
| TO:      | Ardex NZ Ltd  |
| ATTN:    | Steven Irvine |

|              |                         |                |               |
|--------------|-------------------------|----------------|---------------|
| SAMPLE OF:   | Ardex LQ92              | SAMPLE TYPE:   | As received   |
| SAMPLE TYPE: | Tile Levelling Compound | DATE RECEIVED: | 18/07/2022    |
| SAMPLE DATE: | -                       | DATE TESTED:   | 18-20/07/2022 |
|              |                         | ORDER NO:      | -             |

|                |   |
|----------------|---|
| SPECIFICATION: | Green Building Council of Australia<br>Green Star Design & As Built V1.3-13.1.1B<br>Green Star Interiors V1.3-12.1.1B       |
| DETAILS:       | Max TVOC content in grams per litre (g/L) of ready to use product in the category of 'Primers, sealers and prep coats' = 65 |

### RESULTS

|                                  | Result         | Method                       |
|----------------------------------|----------------|------------------------------|
| Total Non-Volatile Content, %w/w | 99.6           | Oven-drying @ 110°C (60mins) |
| Total Water Content, %w/w        | 0.3            | Karl Fischer titration       |
| Density, g/mL                    | 1.86           | Gravimetry                   |
| Exempt Compounds                 | None specified |                              |

|                                       | Result            | Method               |
|---------------------------------------|-------------------|----------------------|
| Total Volatile Organic Compounds, g/L | Not Detected (<5) | SCAQMD METHOD 304-91 |

**Note: Specification was provided by the client. This sample complies with the specification.**

Analyst

Authorised by

This report relates only to the sample provided.  
**This Report Shall Not Be Reproduced Except in Full**