

# VOC Content Test Certificate

Tuesday, 4<sup>th</sup> August 2015

Manufacturer: Ardex Australia Pty Ltd (7/20 Powers Road, Seven Hills, NSW, 2147)

Sample Description: SUPER LOW VISCOSITY ARDEX RA 142

Date Tested: August 2015 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia Green Star Office Design V3 IEQ-13</b>	<b>SUPER LOW VISCOSITY ARDEX RA 142</b>
Multipurpose Construction Adhesive  70 grams per Litre as VOC content per material	<b>8 grams per Litre as VOC content per material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal  
Consultant



Tuan Duong  
PhD. BEng (Chemical Engineer)  
Consultant



Nick Joy  
BSc(Hons)  
Consultant

**CV150732**