

**ANALYSIS CERTIFICATE**

25 July, 2022

<b>OUR REF:</b>	107772D
<b>TO:</b>	Ardex NZ Ltd
<b>ATTN:</b>	Steven Irvine

<b>SAMPLE OF:</b>	Ardex FG8	<b>SAMPLE TYPE:</b>	As received
<b>SAMPLE TYPE:</b>	Flexible Coloured Grout	<b>DATE RECEIVED:</b>	18/07/2022
<b>SAMPLE DATE:</b>	-	<b>DATE TESTED:</b>	18-20/07/2022
		<b>ORDER NO:</b>	-

<b>SPECIFICATION:</b>	Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B
<b>DETAILS:</b>	Max TVOC content in grams per litre (g/L) of ready to use product in the category of 'General purpose adhesives and sealants' = 50

**RESULTS**


	Result	Method
Total Non-Volatile Content, %w/w	99.9	Oven-drying @ 110°C (60mins)
Total Water Content, %w/w	0.2	Karl Fischer titration
Density, g/mL	1.89	Gravimetry
Exempt Compounds	None specified	

	Result	Method
Total Volatile Organic Compounds, g/L	Not Detected (<5)	SCAQMD METHOD 304-91

**Note: Specification was provided by the client. This sample complies with the specification.**

Analyst H. S. [Signature]

Authorised by [Signature]



This report relates only to the sample provided  
**This Report Shall Not Be Reproduced Except in Full**