

VOC Content Test Certificate

Wednesday 9th March 2022

Supplier: Ardex New Zealand Limited (15 Alfred Street, Onehunga, Auckland, 1061, New Zealand)

Product Description: Ardex X10 Grey

Date Tested: March 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings Materials. ASTM D3960 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Ardex X10 Grey
General Purpose Adhesive and Sealants: 50 grams per Liter	2 grams per Liter as VOC content per material
<p><i>We hereby certify that Ardex X10 Grey is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Luke Morley
BSc (Tech)
Consultant

P22030049