

VOC Content Test Certificate

Monday February 15th, 2010

Supplier: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills NSW 2147)

Sample Description: Ardex WPM 642 Water Based Bonding Adhesive

Date Tested: February 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</p>	<p align="center">Ardex 642 Water Based Bonding Adhesive</p>
<p>Multipurpose Construction Adhesive 70 grams per Litre as VOC content material</p>	<p><1grams per Litre as VOC content material</p>
<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p>	<p align="center">Ardex 642 Water Based Bonding Adhesive</p>
<p>Multipurpose Construction Adhesive 70 grams per Litre as VOC content material</p>	<p><1 grams per Litre as VOC content material</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1001-19