

# VOC Content Test Certificate

Thursday 18<sup>th</sup> August 2022

Supplier: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, SEVEN HILLS, NSW 2147, Australia).

Sample Description: ARDEX WPM 002

Date Tested: August 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)


Test Method: ASTM D3960 & ASTM D2369 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

<p align="center"><b>Specification</b></p> <p align="center"><b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3-13.1.1B</b> <b>Green Star Interiors V1.3-12.1.1B</b></p>	<p><b>ARDEX WPM 002</b></p>
<p align="center"><b>Water Proofing Membranes and Sealant Limit:</b> <b>250 grams per litre</b></p>	<p><b>&lt;1 gram per litre as VOC content per material</b></p>
<p align="center"><b>Meets GBCA VOC Content Requirement</b></p>	<p><b>Yes</b></p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dr. Tuan Duong  
PhD, BE (Chem. Eng.)  
Senior Consultant



Travis Hale  
BSc (Biotechnology)  
Senior Consultant

**P22070055**