

# VOC Content Test Certificate

Thursday, 27<sup>th</sup> June 2019

Supplier: Ardex Australia Pty Ltd (7/20 Powers Road, Seven Hills, NSW, 2147, Australia)

Sample Description: Ardex WPM 1500

Date Tested: 24<sup>th</sup> June 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

|   |   |
|---|---|
| <p><b>Specification</b></p> <p><b>Green Building Council of Australia</b><br/> <b>Green Star Design &amp; As Built V1.1 13.1.1</b><br/> <b>Green Star Interiors V1.1 12.1.1B</b></p>                | <p><b>Ardex WPM 1500</b></p>                                |
| <p>Acoustic sealants, architectural sealants, waterproofing membranes and sealants, fire retardant sealants and adhesives:<br/>                 250 grams per Litre as VOC content per material</p> | <p><b>3 grams per Litre as VOC content per material</b></p> |
| <p><i>We hereby certify Ardex WPM 1500 is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p>                               |   |



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant



Tuan Duong  
 BE (Chem. Eng.)  
 Consultant



Luke Morley  
 BSc (Tech)  
 Consultant

CV190661