

VOC Content Test Certificate

Thursday 18th August 2022

Supplier: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, SEVEN HILLS, NSW 2147, Australia).

Sample Description: ARDEX WPM 300 Grey

Date Tested: August 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 & ASTM D2369 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

<p align="center">Specification</p> <p align="center">Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B</p>	<p align="center">ARDEX WPM 300 Grey</p>
<p align="center">Water Proofing Membranes and Sealant Limit: 250 grams per litre</p>	<p align="center">23 grams per litre as VOC content per material</p>
<p align="center">Meets GBCA VOC Content Requirement</p>	<p align="center">Yes</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

P22070055