

# VOC Content Test Certificate

Monday February 15<sup>th</sup>, 2010

Supplier: Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, Seven Hills NSW 2147)

Sample Description: Ardex WPM 615 Sheet Membrane

Date Tested: February 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>	
<b>Green Building Council of Australia</b>	<b>Ardex WPM 615 Sheet Membrane</b>
<b>Green Star Office Design V2 IEQ-13</b>	
<b>Green Star Office Interiors V1.1 IEQ-11</b>	
Architectural Sealant 250 grams per Litre	<b>74 grams per Litre</b>
<b>Specification</b>	
<b>Green Building Council of Australia</b>	<b>Ardex WPM 615 Sheet Membrane</b>
<b>Green Star Office Design V3 IEQ-13</b>	
Architectural Sealant 250 grams per Litre	<b>74 grams per Litre</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F1001-19